

# ADPH Fire Alarm Inspection & Testing Summary\*

\*This form is to be filled out by the representative of a fire alarm company, holding a valid business license, the company's own Inspection and Testing Report shall be attached. This summary page is not a substitute for the required NFPA 72 Inspection and Testing form or the code's inspection and testing requirements.

---

Name and address of facility.

- |   |   |   |     |
|---|---|---|-----|
| 1. System was found in service and left in service.   | Y | N |     |
| 2. Performed visual inspection of entire system throughout the facility.  | Y | N |     |
| 3. All alarm initiating devices were tested and initiated an alarm signal.  | Y | N |     |
| 4. All alarm notification devices operated properly.  | Y | N |     |
| 5. All supervisory devices were tested and initiates a supervisory signal.  | Y | N |     |
| 6. The system has two means of communicating a signal to the monitoring company.  | Y | N |     |
| 7. The system transmits alarm signals to monitoring company.  | Y | N |     |
| 8. Magnetic locking devices, if installed, released upon fire alarm activation and loss of power to the fire alarm control panel. | Y | N | N/A |
| 9. Sensitivity testing of smoke detectors accomplished (every two years).   | Y | N | N/A |

**(Explain any no "N" answers in the remarks area. Any no "N" or noncompliant areas noted on the Inspection & Test Report shall be referenced below.)**

**Remarks:**

---

---

---

---

---

---

---

---

Name printed and Signature of Inspector

---

Date of Inspection

---

Signature of Owner or Administrator